


Sound Baffles

The baffle is normally installed from the top of the curb and screwed or riveted to the top of the curb.



Specifications:

Frame: 18 ga. (.050) galvanized steel construction

Insulation: 1½" thick 3 lb. density rigid fiberglass insulation

Baffles are 5" on centers

Standard height is 6" plus 1½" frame

TAG	Quantity	A	B	Options

SB-12-2001

