



SUGGESTED SPECIFICATIONS FOR CEILING RADIATION DAMPERS

All ceiling register and grille penetrations in fire rated ceilings shall be protected by a **Underwriters Laboratories Fire Resistance Classified Ceiling Radiation Damper**. Fire dampers with 1½ or 3 hour ratings for walls or floors are not to be used in fire rated ceiling openings due to the fact they do not provide the necessary heat barrier. Dampers shall have pass test described under U.L. Standard 555C and are labeled such for use in any fire-resistive floor or roof-ceiling assembly with a restrained and/or unrestrained assembly rating of 3 hours or less. Damper shall be supplied with a 165°F or 212°F (specify) fusible link. All installation shall be in accordance with manufacture's published installation instructions and U.L. Standard 555C. Dampers shall be **Leader** or pre-approved equal.



Mailing Address: P.O. Box 40913
Business Address: 2509 Cruzen Street
DIVISION OF LEADER INDUSTRIES, INC.

Nashville, Tennessee 37204
Nashville, Tennessee 37211

PHONE: 615-256-3500
FAX: 800-388-3806