


# LEADER

## Dampers & Louvers

### Severe Duty Miami-Dade County Approved 4" Horizontal Blade Louvered Penthouse Model DC-PHB



DC-PHB is designed specifically to meet the following Miami-Dade County test requirements and protocols:

- PA 201-94 (Large Missile Impact Test)
- PA 202-94 (Uniform Static Air Pressure Test)
- PA 203-94 (Cycle Wind Loading Test)

Based on testing of a throat size of 88" x 100" x 84"h sample with a maximum design load pressure of 85-psf.

#### Features:

- Shipped Fully Assembled
- Easily Installed From Outer Perimeter
- Miami-Dade County Approved as a Fan Enclosure

#### Available with many optional features including:

- Finishes
- Hinged Roof
- Fan Mounting Collar
- Insulated Roof Hood
- Filters
- Many More Optional Features

Max Wind Load  
+/- 85 psf

Shown with Miami-Dade approved roof curb sold separately.



Intake



Side View of  
Single Louver

Notice of Acceptance Number 07-1010.12

**LEADER**  
Dampers & Louvers

P.O. Box 40913  
Nashville, TN 37204  
www.leaderindustries.com  
A Division of Leader Industries, Inc.

